



STATE OF CALIFORNIA  
THE RESOURCES AGENCY  
DEPARTMENT OF WATER RESOURCES  
WATER WELL DRILLERS REPORT

Do not fill in  
No. 07924

Notice of Intent No. \_\_\_\_\_  
Local Permit No. or Date \_\_\_\_\_

State Well No. \_\_\_\_\_  
Other Well No. \_\_\_\_\_

(1) OWNER: Name Bob Miller  
Address 501 No. Main St.  
City Templeton, CA. 93465 Zip \_\_\_\_\_  
(2) LOCATION OF WELL (See instructions):  
County SLO Owner's Well Number \_\_\_\_\_  
Well address if different from above \_\_\_\_\_  
Township 27S Range 14E Section 29  
Distance from cities, roads, railroads, fences, etc.  
Camp Rd. & Hwy. 41 E. Lot #

(12) WELL LOG: Total depth 315 ft. Depth of completed well 300 ft.  
from ft. to ft. Formation (Describe by color, character, size or material)

0	4	Top Soil
4	10	Shale Gravel
10	30	Yellow Clay & Coarse Sand
30	45	Coarse Sand
45	50	Yellow Clay & Sand
50	75	Blue Clay
75	90	Shale Gravel
90	115	Blue Clay
115	130	Shale Gravel
130	170	Yellow Clay
170	175	Shale Gravel & Sand
175	180	Blue Clay
180	200	Coarse Sand & Gravel
200	210	Blue Clay
210	255	Yellow Clay & Stringers of Gravel
255	265	White Shale
265	273	Blue Clay
273	276	White Shale
276	295	Blue Clay & Stringers of Gravel
295	300	Blue Shale

(3) TYPE OF WORK:  
New Well  Deepening   
Reconstruction   
Reconditioning   
Horizontal Well   
Destruction  (Describe destruction materials and procedures in Item 12)  
(4) PROPOSED USE:  
Domestic   
Irrigation   
Industrial   
Test Well   
Stock   
Municipal   
Other

WELL LOCATION SKETCH \_\_\_\_\_  
(5) EQUIPMENT:  
Rotary  Reverse   
Cable  Air   
Other  Bucket   
(6) GRAVEL PACK:  
Yes  No  Size 1/2"  
Diameter of bore 10 5/8"  
Packed from 20 to 300

(7) CASING INSTALLED: Steel  Plastic  Concrete   
(8) PERFORATIONS:  
Type of perforation or size of screen

From ft.	To ft.	Dia. in.	Cage or Wall	From ft.	To ft.	Slot size
0	300	6	.315	0	160	Blank
				160	300	Perf.

(9) WELL SEAL:  
Was surface sanitary seal provided? Yes  No  If yes, to depth 20 ft.  
Were strata sealed against pollution? Yes  No  Interval \_\_\_\_\_ ft.  
Method of sealing Cement

(10) WATER LEVELS:  
Depth of first water, if known 170' ft.  
Standing level after well completion 121' ft.

(11) WELL TESTS:  
Was well test made? Blow Test: 5 gpm at 140'  
Type of test Pump  Bailor   
Depth to water at start of test \_\_\_\_\_ ft. At end of test \_\_\_\_\_ ft.  
Discharge \_\_\_\_\_ gal/min after \_\_\_\_\_ hours Water temperature \_\_\_\_\_  
Chemical analysis made? Yes  No  If yes, by whom? \_\_\_\_\_  
Was electric log made? Yes  No  If yes, attach copy to this report

NOTE: Any person removing the cap from this well other than Miller Drilling Co. or authorized contractor approved by us will void all structural warranties.  
Work started 4/9/79 19\_\_\_\_ Completed 4/10/79 19\_\_\_\_

WELL DRILLER'S STATEMENT:  
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.  
SIGNED [Signature] (Well Driller)  
NAME Miller Drilling Co. (Person, firm, or corporation) (Typed or printed)  
Address 501 No. Main St.  
City Templeton, CA. 93465 Zip \_\_\_\_\_  
License No. 324634 Date of this report: 4/16/79